

TOWN OF KEARNY

2014 Annual Drinking Water Quality Report

July 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is ground water drawn from a clean water source 120-600 feet below the Gila River Basin.

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact **Anna Flores, Town Manager, 520-363-5547, 7:00 a.m. – 5:30 p.m., Monday through Thursday, at the Kearny Town Hall, 912-C Tilbury Rd., Kearny, Arizona 85137.** We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Council meetings. They are held on the third Monday of every month, 7:30 p.m., Council Chambers, Kearny Town Hall, 912-C Tilbury Rd., Kearny, AZ 85137.

Town of Kearny Utilities routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2013.

ADDITIONAL INFORMATION IS AVAILABLE FROM THE SAFE DRINKING WATER HOTLINE (1-800-426-4791)

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by

calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Arizona Department of Environmental Quality implemented the backflow prevention program in 1994 to protect the Town's drinking water system from the possibility of contamination or pollution by preventing the backflow of contaminants and pollutants into the public potable water supply systems. The Town of Kearny has participated in the backflow prevention program since 1994, and all customers that are required to have a backflow prevention device have complied with the requirements.

The Town of Kearny's water system is under the supervision of a certified operator through the Arizona Department of Environmental Quality. The Town of Kearny strives to continue to be diligent in providing to its customers a safe water system. Please call the Kearny Town Hall, 520-363-5547, 7:00 a.m. – 5:30 p.m., Monday through Thursday, if you have any questions.

We ask that all customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

TEST RESULTS

Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants						
1. Total Coliform Bacteria	No	0	CFU Per 100 ml	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
2. Fecal coliform and E.coli	No	ND		0	a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or E. coli positive	Human and animal fecal waste
3. Turbidity	No	NA		n/a	TT	Soil runoff

The Town of Kearny will not be providing copies of the CCR by mail or other direct delivery methods. The 2014 Annual Drinking Water Quality Report is posted on the Town of Kearny website and reports are available to the public upon request.